

City of



Minneapolis

DEPARTMENT OF INSPECTIONS

DONALD A. ERICKSON, DIRECTOR
220 GRAIN EXCHANGE S30-2642
MINNEAPOLIS, MINNESOTA 55415

US EPA RECORDS CENTER REGION 5



434047

July 12, 1971

F. W. Eaton
Project Engineer
W. R. Grace & Co.
62 Whittemore Ave.
Cambridge, Mass.

Dear Mr. Eaton:

On the basis of the preliminary drawings along with a cover letter sent to me dated July 6, 1971, consider this letter an installation permit from the Air Pollution Control Division of the City of Minneapolis for the installation of a Bag House Filter - Model C-4-18 on the W. R. Grace Co. plant at 1720 Madison N. E., Minneapolis.

I showed these preliminary plans to Mr. Steve Torosian of the Engineering Section, Department of Inspections. He indicated that a building permit would be required. He said that when plans are brought in for the permit they should include a footing detail of the existing loading dock together with the weight of the bag house and supporting frame. Also a framing plan of the new construction at the roof of the existing building.

Sincerely,

Robert L. Lines
Supervisor
Air Pollution Control

RLL/d